



RFQ # REC-2018-01

ADDENDUM #1

Issued February 06, 2018

This Addendum is issued to clarify the above mentioned RFQ regarding the Washago Centennial Park Washroom Hydro.

1. Emergency Lighting

- a) Emergency Lighting to be installed in all rooms. The shower room and service/storage room have emergency lighting.

2. BX Cable

- a) The existing BX cable is to be replaced if necessary. Any outdated wiring is to be brought up to Code. (Service Provision #5).

3. Electrical Panel for Pump

- a) This item is deleted from the scope of work. Township staff will confirm in early spring when the meter pit is opened to verify what is required. This review will be completed in order that the work can be completed at the same time as the awarded work. There are no drawings of the pit, pump and associated lines on record.