

COLDWATER

**Water Supply and
Distribution System
DWS# 220001110**



2019 Summary Report

**For the period of January 1, 2019
To December 31, 2019**

*Prepared by: The Township of Severn
1024 Hurlwood Lane
Severn, Ontario L3V 0Y6
Tel: (705) 325-2315
Fax: (705) 325-1247*

Issued January 2020

Table of Contents

OVERVIEW AND BACKGROUND	3
Safe Drinking Water Act	3
Municipal Drinking Water Licensing Program	3
INTRODUCTION	4
System and Process Description	4
Source Water	4
Raw Water Characteristics	4
Water Treatment	4
Water Distribution	4
REGULATORY COMPLIANCE	5
Ontario Regulation 170/03	5
Ontario Regulation 169/03	5
Ontario Regulation 128/04	5
Wells Regulation 903	5
Drinking Water Quality Management Standard (DWQMS)	5
Municipal Drinking Water License	5
Drinking Water Works Permit License	6
Summary of Non-Compliance and Adverse Water Quality Incidents	6
DWQMS & Municipal Drinking Water Licensing Program	6
Third Party Audit and Accreditation	6
Internal Audit	6
Management Review	6
SYSTEM IMPROVEMENTS AND MAINTENANCE	7
MICROBIOLOGICAL TESTING	7
E. Coli and Total Coliform	7
Heterotrophic Plate Count (HPC)	8
Chlorine Residual and Turbidity	8
CHEMICAL TESTING	8
Understanding Chemical Test Results	9
WATER QUANTITY	12
APPENDIX A – FLOW CHARTS	14

Overview and Background

Safe Drinking Water Act






Safe Drinking Water Act Ontario Regulation 170/03, Schedule 22-2, requires that owners of municipal drinking water systems prepare a Summary Report and present this report to the members of Municipal Council by March 31st of each year. The report is prepared for the previous calendar year and the following criteria must be included as per the regulation:

- a) List the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and orders applicable to the system that were not met during the period covered by the report.
- b) For each requirement referred to in clause (a) that was not met specify the duration of the failure and the measures that were taken to correct the failure.
- c) A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
- d) A comparison of the summary referred to in (c) to the rated capacity and flow rates approved by the system's certificate of approval, drinking water works permit or municipal drinking water license.

This Summary Report also serves as a comprehensive review of the systems performance of the drinking water system as it relates to regulations and criteria that fall under the municipal drinking water licensing program.

Municipal Drinking Water Licensing Program

A Municipal Drinking Water License (MDWL) is required in Ontario to operate the drinking water system. The Municipal Drinking Water License (# 148-101 Issue Number 2) was re-issued in May of 2016 and is valid until May 25, 2021. The reissuance was initiated by the Ministry of Environment, Conservation and Parks (MECP) due to regulatory amendments that required timelines to be outlined in the MDWL. There are five requirements that must be achieved in order to obtain an MDWL:

-  A valid Drinking Water Works Permit (148-201 Issue Number 2)
-  A valid Permit to Take Water for each source (#6005-8ZSPHN)
-  An Operational Plan
-  Must have an Accredited Operating Authority (0124837-DWQ3-C0122097)
-  A Financial Plan approved by Council

Introduction

System and Process Description

The Corporation of the Township of Severn is the owner and operator of the Coldwater Water Supply and Distribution System. It currently has 580 residential and commercial service connections. It also supplies water to Riverwalk Estates distribution system that is comprised of 46 connections. Coldwater is classified as a Class 1 Water Treatment system and a Class 1 Water Distribution system.

Source Water

The Coldwater Water Supply and Distribution System obtains its raw water from any one of two (2) 200mm diameter drilled wells (Well 1 & 3) located on the pump house property or from a 150mm diameter drilled well (Well 2) located across the street from the pump house.

Raw Water Characteristics

The raw water is of low turbidity and is of acceptable ph. Due to the depth of the source water the temperature is relatively constant.

Water Treatment

Water entering the pump house is partially softened with a Kinetico water softener and then filtered using two Calgon model 8 GAC filters operated in series. Filtered water is then disinfected using sodium hypochlorite. Treated water is then stored in an underground reservoir.

Water is pumped to the distribution system via three vertical turbine high lift pumps. A fire pump is also installed to provide adequate flow in the event of a fire. Pressure in the distribution system is maintained at approximately 65 PSI by five 450L pressure tanks.

Online analyzers monitor and record raw and treated water flow rates, treated water turbidity, free chlorine residual and ph. Level sensing probes record well levels. The plant is also equipped with full SCADA control.

Standby power is provided to the building and all of its equipment by a 250 kW standby diesel generator.

Water Distribution

The distribution system is comprised of 8.9 km of water main ranging in size from 50 mm to 300 mm. There are 10 sample stations, 5 blow-offs, 83 fire hydrants and 3 private hydrants in the Coldwater system.

Regulatory Compliance

All municipally owned and operated water systems are governed under the Safe Drinking Water Act, 2002, Ontario Water Resources Act (OWRA), and associated regulations. The following regulations, and associated standards and documents, are all applicable, and most relevant, to the compliant operation of the Township of Severn's Drinking Water system:

Ontario Regulation 170/03

This regulation includes requirements for:

- 🔹 Sampling and analytical testing (microbiological and chemical)
- 🔹 Adverse water quality incidents
- 🔹 Corrective actions
- 🔹 Continuous water quality monitoring

Ontario Regulation 169/03

This regulation includes requirements for:

- 🔹 Water Quality Standards

Ontario Regulation 128/04

This regulation includes requirements for:

- 🔹 Classifications of Drinking Water Systems
- 🔹 Certifications and responsibilities of Operators
- 🔹 Proper record keeping of the drinking water system

Wells Regulation 903

This regulation includes requirements for:

- 🔹 Well maintenance
- 🔹 Well specifications

Drinking Water Quality Management Standard (DWQMS)

This Standard specifies:

- 🔹 Minimum requirements for the Quality Management System to allow for the accreditation of the Operating Authority

Municipal Drinking Water License

This document includes requirements for:

- 🔹 Specific conditions / testing / monitoring
- 🔹 Flow limits through the treatment system
- 🔹 Regulatory relief conditions
- 🔹 Operations & Maintenance manual criteria

Drinking Water Works Permit License

This document includes criteria for:

- 💧 Making alterations to the system

Summary of Non-Compliance and Adverse Water Quality Incidents

There were three (3) non-compliance or AWQI incidents that occurred in 2019.

- 1) March 26, 2019- AWQI was filed for pressure loss. Pressure loss caused by water main service by the utilities department. Boil water was implemented. Two sets of samples were taken, results were "0" for E-Coli and total coliform.
- 2) May 29, 2019- AWQI was filed for pressure loss. Pressure loss caused from flushing and closed distribution valve. Boil water was implemented. Two sets of samples were taken, results were "0" for E-Coli and Total Coliform.
- 3) July 31, 2019- AWQI filed for Total Coliform present in water sample. Resampled and two sets of samples were taken, results were "0" for E-Coli and Total Coliform.

DWQMS & Municipal Drinking Water Licensing Program

Third Party Audit and Accreditation

On an annual basis, a third-party accreditation authority conducts an audit to determine whether the Quality Management System conforms to the requirements of the MECP Drinking Water Quality Management Standard (DWQMS).

In November 2019, NSF International completed a satellite audit with no non-conformances noted.

Internal Audit

As per the DWQMS, an internal audit is to be conducted once per year.

September 23-24, 2019 an internal audit was conducted by Aet Group Inc. The findings were included during Management Review.

Management Review

As per the DWQMS, an annual Management Review is to be conducted and findings conveyed to the Owner. Management Reviews were conducted June 5 and December 10, 2019. The review included findings from the internal and external audits, MECP inspections and other prescribed items.

System Improvements and Maintenance

The following maintenance and improvements were carried out in 2019 in order to provide the highest possible drinking water quality:

1. The water distribution system was directionally flushed to maintain drinking water quality.
2. Over 25% of the main valves in the distribution system were exercised to ensure their reliability.
3. The standby generator was tested under load monthly to ensure reliability.
4. All critical alarms were tested monthly to ensure reliability.
5. Drinking water quality was tested at the water treatment plant and in the distribution system weekly.
6. Swabbed 50% of distribution system to improve water quality & delivery.
7. Installed three variable speed drives on distribution high lift pumps.
8. Installed three check valves.
9. Replaced shut off valve and portion of distribution supply line at Water Treatment Plant.
10. Replaced distribution flow meter.
11. Replaced all three well pump flow meters.

Microbiological Testing

E. Coli and Total Coliform

Bacteriological samples, to be tested for E. Coli and Total Coliforms, are taken weekly from the raw and treated water at the facility and from the distribution system. Extra samples are taken after major repairs or maintenance work as per Regulation 170/03. Any E. Coli or Total Coliform results above 0 in treated water must be reported to the MECP and Medical Officer of Health (MOH). Resamples and other required actions are undertaken as quickly as possible. The results from the 2019 sampling program are shown on the table below.

	Number of Samples	Range of E-Coli Results (cfu/100ml) (Min – Max) MAC=0	Range of Total Coliform Results (cfu/100ml) (Min – Max) MAC=0
Raw	156	0 - 0	0 - 0
Treated	219	0 - 0	0 - 15

Heterotrophic Plate Count (HPC)

HPC analyses are completed weekly from the distribution water for large systems. HPC should be less than 500 colonies (cfu) per 1mL. Results over 500 colonies (cfu) per 1 mL may indicate a change in water quality but it is not considered an indicator of unsafe water. The results from the 2019 sampling program are shown on the table below.

	Number of Samples	Range of HPC Results (cfu/1ml) (Min – Max)
Distribution	129	0 - 30

Chlorine Residual and Turbidity

Free chlorine levels of the treated water are monitored continuously at the discharge point of the treatment facility. In the distribution system, free chlorine is checked twice weekly at various locations. As a target, free chlorine residual within the distribution system should be above 0.20 mg/L. A free chlorine level lower than 0.05 mg/L must be reported to the MECP and corrective action taken. There were no reportable incidents in 2019. The results from the 2019 sampling program are shown on the table below.

Turbidity of treated water is continuously monitored at the treatment facility, as a change in turbidity can indicate an operational problem. Turbidity of the wells are checked monthly. Turbidity is measured in Nephelometric Turbidity Units (NTU). The results from the 2019 sampling program are shown on the table below.

Parameter	Number of Tests	Range of Results (Min – Max) Average
Chlorine residual in distribution (mg/L)	363	(0.62 - 1.20) 0.91
Chlorine residual after treatment (mg/L)	Continuous	(0.77 - 1.22) 0.99
Turbidity after treatment (NTU)	Continuous	(0.20 - 0.50) 0.29

Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for different chemical parameters. The latest results for all parameters are provided in Appendix A. The sampling frequency varies for different types and sizes of water systems and chemical parameters. If the concentration of a parameter is above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once

every three months is required by the Regulation. Where concerns regarding a parameter exist, the MECP can also require additional sampling. Information on the health effects and allowable limits of components in drinking water may be found on the MECP web page.

Understanding Chemical Test Results

Tables below are shown with concentrations units of either milligrams per litre (mg/L) or micrograms per litre (µg/L) : 1 mg/L is equal to 1000 µg/L. The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in Municipal Limit (MDL) is the lowest amount to which the laboratory can confidently measure. A result of “ND” stands for “Not Detected” and means that the concentration of the chemical is lower than the laboratory’s equipment is capable of measuring.

Nitrate and Nitrite samples are required every 3 months in normal operation

Parameter	Result Range Min - Max	Average	MAC (mg/L)	MDL (mg/L)
Nitrite (mg/L)	0.003 - 0.003	0.003	1	0.003
Nitrate (mg/L)	0.006- 0.006	0.006	10	0.006

A Trihalomethane (THM) sample is required every 3 months from the distribution system

Parameter	Annual	Result (Avg.)	MAC (µg/L)	MDL (µg/L)
THM	2019	14.23	100	0.37

A Haloacetic Acid (HAA) sample is required every 3 months from the distribution system

Parameter	Annual	Result (Avg.)	MAC (µg/L)	MDL (µg/L)
HAA	2019	< 5.3	--	5.3

Summary of the most recent sodium and fluoride results

Parameter	Sample Date	Result (mg/L)	MAC (mg/L)	MDL (mg/L)
Sodium	2019	96.6	20	0.01
Fluoride	2018	0.14	1.5	0.06

Summary of the most recent lead testing results

Parameter	Sample Date	Result Range (Min – Max)	Number of samples	Acceptable Level
Distribution Alkalinity	2019	229 – 234 mg/L	4	30-500 mg/L
Distribution pH	2019	7.0 - 7.7	4	6.5-8.5
Distribution Lead	2019	0.01 - 0.21 µg/L	4	10 µg/L

Summary of the most recent Schedule 23/24 testing as per Regulation 170/03

All results are measured in µg/L unless otherwise stated.

Parameter	Sample Date	Result Value	MAC	MDL
Antimony	Oct. 29, 2019	0.10	6	0.02
Arsenic	Oct. 29, 2019	0.2	25	0.2
Barium	Oct. 29, 2019	259	1000	0.02
Boron	Oct. 29, 2019	75	5000	2
Cadmium	Oct. 29, 2019	0.003	5	0.003
Chromium	Oct. 29, 2019	0.14	50	0.03
Mercury	Oct. 29, 2019	0.01	1	0.01
Selenium	Oct. 29, 2019	0.04	50	0.04
Uranium	Oct. 29, 2019	0.854	20	0.002
Benzene	Oct. 29, 2019	0.32	1	0.32
Carbon tetrachloride	Oct. 29, 2019	0.17	2	0.16
1,2-Dichlorobenzene	Oct. 29, 2019	0.41	200	0.41
1,4-Dichlorobenzene	Oct. 29, 2019	0.36	5	0.36
1,1-Dichloroethylene	Oct. 29, 2019	0.33	14	0.33
1,2-Dichloroethane	Oct. 29, 2019	0.35	5	0.35
Dichloromethane	Oct. 29, 2019	0.35	50	0.35
Monochlorobenzene	Oct. 29, 2019	0.3	80	0.3
Tetrachloroethylene	Oct. 29, 2019	0.35	30	0.35
Trichloroethylene	Jan. 9, 2018	0.44	5	0.44
Vinyl Chloride	Oct. 29, 2019	0.17	1	0.17
Diquat	Oct. 29, 2019	<1	70	1
Paraquat	Oct. 29, 2019	<1	10	1
Glyphosate	Oct. 29, 2019	<1	280	1
PCBs	Oct. 29, 2019	0.04	3	0.04
Benzo(a)pyrene	Oct. 29, 2019	0.004	0.01	0.004
Alachlor	Oct. 29, 2019	0.02	5	0.02

Parameter	Sample Date	Result Value	MAC	MDL
Atrazine+N-daelkylated metabolites	Oct. 29, 2019	0.01	5	0.01
Atrazine	Oct. 29, 2019	0.01	--	0.01
Desethyl atrazine	Oct. 29, 2019	0.01	--	0.01
Azinphos-methyl	Oct. 29, 2019	0.05	20	0.05
Bendiocarb	Jan. 9, 2018	0.01	40	0.01
Carbaryl	Oct. 29, 2019	0.05	90	0.05
Carbofuron	Oct. 29, 2019	0.01	90	0.01
Chlorpyrifos	Oct. 29, 2019	0.02	90	0.02
Diazinon	Oct. 29, 2019	0.02	20	0.02
Dimethoate	Oct. 29, 2019	0.06	20	0.03
Diuron	Oct. 29, 2019	0.03	150	0.03
Malathion	Oct. 29, 2019	0.02	190	0.02
Metolachlor	Oct. 29, 2019	0.01	50	0.01
Metribuzin	Oct. 29, 2019	0.02	80	0.02
Phorate	Oct. 29, 2019	0.01	2	0.01
Prometryne	Oct. 29, 2019	0.03	1	0.03
Simazine	Oct. 29, 2019	0.01	10	0.01
Terbufos	Oct. 29, 2019	0.01	1	0.01
Triallate	Oct. 29, 2019	0.01	230	0.01
Trifluralin	Oct. 29, 2019	0.02	45	0.02
2,4-dichlorophenoxyacetic acid	Oct. 29, 2019	0.19	100	0.19
Bromoxynil	Oct. 29, 2019	0.33	5	0.33
Dicamba	Oct. 29, 2019	0.20	120	0.20
Dichlofop-methyl	Oct. 29, 2019	0.40	9	0.40
MCPA (mg/L)	Oct. 29, 2019	0.00012	0.1	0.00012
Picloram	Oct. 29, 2019	<1	190	1
2,4-dichlorophenol	Oct. 29, 2019	0.15	900	0.15
2,4,6-trichlorophenol	Oct. 29, 2019	0.25	5	0.25
2,3,4,6-tetrachlorophenol	Oct. 29, 2019	0.20	100	0.20
Pentachlorophenol	Oct. 29, 2019	0.15	60	0.15

Water Quantity

Continuous monitoring of flow rates from the supply wells into the treatment system and from the facility into the distribution system is required by Regulation 170/03. The Municipal Drinking Water License and Permit to Take Water issued by the MECP regulate the amount of water that can be utilized over a given time period. A summary of the 2019 flows are provided in the tables below.

FLOW SUMMARY	QUANTITY
Permit to Take Water Limit	Well 1 - 2141 m ³ /day Well 2 - 982.37 m ³ /day Well 3 - 982.37 m ³ /day
Total Taking Limit	2141m ³ /day
Municipal Drinking Water License Limit	3128m ³ /day
2019 Average Daily Flow	365 m ³
2019 Maximum Daily Flow	1083 m ³
2019 Total Amount of Water Supplied	133375 m ³

Summary of Raw Water Flows

Month	Well #1 (m ³)	Well #2 (m ³)	Well #3 (m ³)
January	14458	53	55
February	12766	547	316
March	13937	50	56
April	12859	65	74
May	14390	52	64
June	14222	45	52
July	16800	83	95
August	14316	39	52
September	13500	58	60
October	14312	50	58
November	13746	34	49
December	14367	36	58
TOTAL	171774		

Summary of Distribution Flows

Month	Monthly Total (m ³)	Average Daily Flow (m ³ /day)	Minimum Daily Flow (m ³ /day)	Maximum Daily Flow (m ³ /day)
January	11600	374	253	669
February	9819	351	295	393
March	11029	356	288	436
April	10263	342	277	415
May	11372	367	251	596
June	11189	373	285	433
July	13516	436	294	1083
August	11090	358	280	430
September	10478	349	268	449
October	11047	356	254	525
November	10525	351	256	437
December	11447	368	271	421
TOTAL	133375			

Appendix A – Flow Charts

