



ANNUAL REPORT

Drinking-Water System Number:	220005152
Drinking-Water System Name:	Severn Estates Water Supply and Distribution
Drinking-Water System Owner:	The Corporation of the Township of Severn
Drinking-Water System Category:	Small Municipal Residential
Period being reported:	January 1, 2017 to December 31, 2017

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Township of Severn Administrative Office 1024 Hurlwood Lane Severn, Ontario L3V 0Y6</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

Water for the Severn Estates subdivision is pumped from a 69 m deep drilled well located within the Severn Estates pump house at 4532 Trent Trail. Water is chlorinated using sodium hypochlorite for disinfection and for iron precipitation. It is then filtered using a two-train ceramic filter system for iron removal. Filtered water is stored in a 13.6 m³ underground concrete reservoir. Treated water is pumped to the distribution system by two high lift pumps and pressure is maintained by three hydro pneumatic pressure tanks. The Severn Estates water system was constructed in the 1970's of PVC piping. There is one sampling station and three blow offs. There are no fire hydrants connected to the distribution system. It serves 23 homes located on Trent Trail.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Replaced 2" coupler on watermain - \$4,700
 New Sample Station - \$2,700
 New SCADA computer - \$5,400
 Two new peristaltic chlorine pumps - \$8,700
 Repaired 4" distribution header - \$500

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
May 25, 2017	Watermain leak (Loss of pressure – Boil Water Advisory)	Potable water leaking from a break at 2" coupler.	N/A	Replaced coupler. Sampled. Sample results were compliant.	May 25, 2017



July 26, 2017	Total Coliform	2 CFU	mg/L	Resampled. Resample results were compliant.	July 26, 2017
Oct. 13, 2017	Repair distribution header (Loss of pressure – Boil Water Advisory)	Potable water leaking from fitting on distribution header.	N/A	Replaced fitting and associated piping. Sampled. Sample results were compliant.	Oct. 13, 2017

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw – Well 1	52	0 - 0	0 - 4	0	N/A
Treated	52	0 - 0	0 - 0	0	N/A
Distribution	58	0 - 0	0 - 2	52	0 - 140

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity – Well 1	12	0.12 – 0.84 NTU
Turbidity	8760	0 – 5 NTU
Chlorine	8760	0 - 5
Chlorine Free Residual Distribution System	104	0.80 – 2.07
Fluoride (If the DWS provides fluoridation)	N/A	

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Oct. 26, 2015	<0.02	µg/L	No
Arsenic	Oct. 26, 2015	0.7	µg/L	No



Barium	Oct. 26, 2015	268	µg/L	No
Boron	Oct. 26, 2015	65.8	µg/L	No
Cadmium	Oct. 26, 2015	<0.003	µg/L	No
Chromium	Oct. 26, 2015	0.58	µg/L	No
*Lead	N/A			
Mercury	Oct. 26, 2015	<0.01	µg/L	No
Selenium	Oct. 26, 2015	0.28	µg/L	No
Sodium	Oct. 19, 2017	51.9	mg/L	Yes
Uranium	Oct. 26, 2015	0.260	µg/L	No
Fluoride	Oct. 21, 2013	0.14	mg/L	No
Nitrite	Jan. 9, 2017 Apr. 4, 2017 Jul. 10, 2017 Oct. 4, 2017	0.003 0.003 0.003 0.003	mg/L mg/L mg/L mg/L	No No No No
Nitrate	Jan. 9, 2017 Apr. 4, 2017 Jul. 20, 2017 Oct. 4, 2017	0.020 0.020 0.021 0.006	mg/L mg/L mg/L mg/L	No No No No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing			
Distribution	2	0.59 – 0.62	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Oct. 26, 2015	<0.02	µg/L	No
Aldicarb	Oct. 26, 2015	<0.01	µg/L	No
Aldrin + Dieldrin	Oct. 26, 2015	<0.01	µg/L	No
Atrazine + N-dealkylated metabolites	Oct. 26, 2015	<0.01	µg/L	No
Azinphos-methyl	Oct. 26, 2015	<0.05	µg/L	No
Bendiocarb	Oct. 26, 2015	<0.01	µg/L	No
Benzene	Oct. 26, 2015	<0.32	µg/L	No
Benzo(a)pyrene	Oct. 26, 2015	<0.004	µg/L	No
Bromoxynil	Oct. 26, 2015	<0.33	µg/L	No
Carbaryl	Oct. 26, 2015	<0.05	µg/L	No
Carbofuran	Oct. 26, 2015	<0.01	µg/L	No



Carbon Tetrachloride	Oct. 26, 2015	<0.16	µg/L	No
Chlordane (Total)	Oct. 26, 2015	<0.01	µg/L	No
Chlorpyrifos	Oct. 26, 2015	<0.02	µg/L	No
Cyanazine	Oct. 26, 2015	<0.03	µg/L	No
Diazinon	Oct. 26, 2015	<0.02	µg/L	No
Dicamba	Oct. 26, 2015	<0.20	µg/L	No
1,2-Dichlorobenzene	Oct. 26, 2015	<0.41	µg/L	No
1,4-Dichlorobenzene	Oct. 26, 2015	<0.36	µg/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Oct. 26, 2015	<0.01	µg/L	No
1,2-Dichloroethane	Oct. 26, 2015	<0.35	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Oct. 26, 2015	<0.33	µg/L	No
Dichloromethane	Oct. 26, 2015	<0.35	µg/L	No
2-4 Dichlorophenol	Oct. 26, 2015	<0.15	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Oct. 26, 2015	<0.19	µg/L	No
Diclofop-methyl	Oct. 26, 2015	<0.40	µg/L	No
Dimethoate	Oct. 26, 2015	<0.03	µg/L	No
Dinoseb	Oct. 26, 2015	<0.36	µg/L	No
Diquat	Oct. 26, 2015	<1	µg/L	No
Diuron	Oct. 26, 2015	<0.03	µg/L	No
Glyphosate	Oct. 26, 2015	<1	µg/L	No
Haloacetic Acids (HAA5) (NOTE: show latest annual average)	2017 Average	20.88	µg/L	No
Heptachlor + Heptachlor Epoxide	Oct. 26, 2015	<0.01	µg/L	No
Lindane (Total)	Oct. 26, 2015	<0.01	µg/L	No
Malathion	Oct. 26, 2015	<0.02	µg/L	No
Methoxychlor	Oct. 26, 2015	<0.01	µg/L	No
Metolachlor	Oct. 26, 2015	<0.01	µg/L	No
Metribuzin	Oct. 26, 2015	<0.02	µg/L	No
Monochlorobenzene	Oct. 26, 2015	<0.3	µg/L	No
Paraquat	Oct. 26, 2015	<1	µg/L	No
Parathion	Oct. 26, 2015	<0.02	µg/L	No
Pentachlorophenol	Oct. 26, 2015	<0.15	µg/L	No
Phorate	Oct. 26, 2015	<0.01	µg/L	No
Picloram	Oct. 26, 2015	<1	µg/L	No
Polychlorinated Biphenyls(PCB)	Oct. 26, 2015	<0.04	µg/L	No
Prometryne	Oct. 26, 2015	<0.03	µg/L	No
Simazine	Oct. 26, 2015	<0.01	µg/L	No
THM (NOTE: show latest annual average)	2017 Average	89.25	µg/L	No
Temephos	Oct. 26, 2015	<0.01	µg/L	No
Terbufos	Oct. 26, 2015	<0.01	µg/L	No
Tetrachloroethylene	Oct. 26, 2015	<0.35	µg/L	No
2,3,4,6-Tetrachlorophenol	Oct. 26, 2015	<0.20	µg/L	No
Triallate	Oct. 26, 2015	<0.01	µg/L	No
Trichloroethylene	Oct. 26, 2015	<0.44	µg/L	No
2,4,6-Trichlorophenol	Oct. 26, 2015	<0.25	µg/L	No

2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Oct. 26, 2015	<0.22	µg/L	No
Trifluralin	Oct. 26, 2015	<0.02	µg/L	No
Vinyl Chloride	Oct. 26, 2015	<0.17	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
THMs	89.25	µg/L	2017 Average
Sodium	51.9	mg/L	October 19, 2017